



**JABATAN LAUT MALAYSIA
MARINE DEPARTMENT MALAYSIA**

MALYSIAN SHIPPING NOTICE

Marine Department HQ, Peninsular Malaysia, PO. Box 12, 42007 Port Klang, Malaysia.
Tel: 03 33467777 Fax: 03 31685020 E-mail: kpgr@marine.gov.my Web site: <http://www.marine.gov.my>

Notis kepada pemilik kapal serta orang yang mempunyai kepentingan kepada kebenaran pengeluaran sijil-sijil statutory.

Notice to ship owners and persons with interest toward the delegation of statutory certification.

PERIODICAL INSPECTION AND MAINTENANCE OF PERMANENTLY INSTALLED FIRE EXTINGUISHING SYSTEMS, PORTABLE FIRE EXTINGUISHERS AND AIR CYLINDERS OF BREATHING APPARATUS

With reference to the above subject, please note the following requirements which will henceforth apply to Malaysia Registered Ships.

1. General

1.1 All types of permanently installed fire-fighting systems, all types of portable fire extinguishers and breathing apparatus air cylinders must be subjected to periodical inspection and maintenance every year by approved shore based service stations or related government agency.

1.2 The attending surveyor may require, based on the results of a periodical inspection, certain containers to be, also, tested hydrostatically.

1.3 Hydrostatic testing is also required after repair.

1.4 Where the loss of content exceeds 10% for CO₂ and 5% for halon, the container must be recharged.

2. Permanently installed fire-fighting systems

2.1 Fixed gas fire-extinguishing systems

1. The quantity of medium in containers must be checked every 12 months
2. Periodic hydrostatic testing of high pressure containers must be carried out for not less than 10% of the containers during each 10 years period or 100% after 20 years.
3. The test pressure shall not be less than 25 N/mm² for CO₂ containers and 1,5 times the working pressure for Halon containers.
4. Fire-extinguishing systems using Halon 1211, 1301, and 2402 and perfluorocarbons is prohibited.

2.2 Fixed foam fire-extinguishing systems in machinery spaces

The first periodical control of foam concentrates stored on board shall be performed after a period of 3 years and, after that, every year.

3. Portable fire extinguishers

3.1 Water and foam

1. The charge must be replaced every 12 months
2. Containers which are permanently under pressure must be tested hydrostatically every 5 years. Containers which are not kept under pressure must be tested every 10 years.
3. The test pressure shall not be less than 1,5 times the working pressure or 2 N/mm² if the working pressure is unknown.

3.2 CO₂

1. The charge must be checked every 12 months and replaced at 5 year intervals
2. Containers must be hydrostatically tested every 10 years.
3. The test pressure shall not be less than 25 N/mm²

3.3 Halon and Powder with shell kept under pressure

1. The charge must be replaced every 2 years.
2. Containers must be hydrostatically tested every 10 years
3. The test pressure shall not be less 1,5 times the working pressure or 2 N/mm² if the working pressure is unknown.

3.4 Powder with shell not kept under pressure

1. The charge must be checked every 12 months and replaced at 5 year intervals.
2. Containers must be hydrostatically tested every 10 years.
3. The test pressure shall not be less than 1.5 times the working pressure or 2 N/mm² if the working pressure is unknown.

3.5 Propellant bottles of non-pressurized fire extinguishers.

1. The content must be checked every year
2. Bottles must by hydrostatically tested every 10 years
3. The test pressure shall not be less than 2 times the working pressure or 25N/mm² in the case of a CO₂ type with safety devices or 35 N/mm² in the case of a CO₂ type without safety devices.

3.6 Spare Charges

1. For fire extinguishers of the same type, capable of being recharged on board, the spare charges must be 100% for the first 10 extinguishers and 50% for the remaining extinguishers but not more than 60 (fractions to be rounded off to next number).
2. For fire extinguishers which cannot be recharged by the crew, additional portable fire extinguishers of the same quantity, type, capacity and number as determined in 1 above should be provided in lieu of spare charges.
3. Instructions for recharging should be carried on board. Only refills approved for the fire extinguisher in question may be used for recharging. Partially emptied extinguishers should also be recharged.

4. Air cylinders for breathing apparatus

4.1 Servicing

1. The compress air inside the cylinder to be change once a year,
2. The cylinders must be hydrostatically tested every 10 years,
3. The test pressure shall not be less than 1,5 times the working pressure

4.2 Spare charges

For every breathing apparatus set, 200% spare charges are required.

Ketua Pengarah Laut/ *Director General of Marine*

Tarikh/Date: 24 DECEMBER 2008